

Topic: Project G6 - supported DSP301/402 parameters

This information describes the G6 supported DSP301/402 parameters.

DSP301 Addr	Object type	Data type	Attr.	SDO Sub-index	Coding	DSP301 Name	Combivis available
1000h	var	Uint32	ro	0		DeviceType	no
1001h	var	Uint8	ro	0		ErrorRegister	no
1018h	array	Uint8	ro	0		Identity object	no
		Uint32	ro	1	14h(KEB)	VendorID	no
		Uint32	ro	2	300000h Combivert G6 Standard	ProductCode	no
		Uint32	ro	3	HighWord OPERatorID LowWord PUApplicationID	RevisionNumber	no
		Uint32	ro	4	xx	KEB_DeviceSerialNumber	no
1600h	array	Uint8	rw	0	No of mapped objects	receive RDO mapping parameter	no
		Uint32	rw	1	Index / Subindex / Bitlength		no
		Uint32	rw	2	Index / Subindex / Bitlength		no
		Uint32	rw	3	Index / Subindex / Bitlength		no
		Uint32	rw	4	Index / Subindex / Bitlength		no
		Uint32	rw	5	Index / Subindex / Bitlength		no
		Uint32	rw	6	Index / Subindex / Bitlength		no
		Uint32	rw	7	Index / Subindex / Bitlength		no
		Uint32	rw	8	Index / Subindex / Bitlength		no
1A00h	array	Uint8	rw	0	No of mapped objects	transmit PDO mapping parameter	no
		Uint32	rw	1	Index / Subindex / Bitlength		no
		Uint32	rw	2	Index / Subindex / Bitlength		no
		Uint32	rw	3	Index / Subindex / Bitlength		no
		Uint32	rw	4	Index / Subindex / Bitlength		no
		Uint32	rw	5	Index / Subindex / Bitlength		no
		Uint32	rw	6	Index / Subindex / Bitlength		no
		Uint32	rw	7	Index / Subindex / Bitlength		no
		Uint32	rw	8	Index / Subindex / Bitlength		no
1C00h	array	Uint8	ro	0 - 4		SyncManager- ComType	no
1C10h	array	Uint16	ro	0	0		no
1C11h	array	Uint16	ro	0	0		no
1C12h	array	Uint16	ro	0	1600h		no
1C13h	array	Uint16	ro	0	1A00h		no



Karl E. Brinkmann GmbH

Försterweg 36-38 • D-32683 Bartrup
fon: +49 5263 401-0 • fax: +49 5263 401-116
net: www.keb.de • mail: info@keb.de

© KEB	
Document	0400-0006
Language	GBR
Date	02-2016